

**NEW YORK STATE THRUWAY AUTHORITY
DEPARTMENT OF ENGINEERING**

**ALBANY, NY
DECEMBER 4, 2024**

**AMENDMENT NO. 1
TO**

**CONTRACT TAS 24-21B
D214922
REPLACEMENT OF THE NYS THRUWAY (I-90) BRIDGE
OVER MOHAWK STREET (ROUTE 28) AT MILEPOST 219.91
IN THE SYRACUSE DIVISION
OF THE NEW YORK STATE THRUWAY
IN HERKIMER COUNTY**

**IN THE LETTING OF
DECEMBER 18, 2024**

NOTE: This amendment shall be attached to and become a part of the Proposal for Contract **TAS 24-21B**.

NOTICE

For Electronic Bidders, the Project’s amended EBSX file will automatically account for any necessary item changes (deletions, changes in quantities, or additions) that this Amendment may describe as being required regarding the project’s estimated cost. Instructions to make physical changes to the Project Proposal’s bid sheets are intended for “paper” Bidders who choose to submit bids via paper.

Questions and Answers for this project are available from the Authority’s website, specifically at: http://www.thruway.ny.gov/netdata/contractors/documents/d214922_tas24-21B_questions-and-answers-12-04-2024.pdf. This document may be updated periodically without formal issuance of an Amendment. Prospective bidders are advised to revisit this link weekly and before proposals are due, for any possible additional questions and answers information.

Additional Supplemental Information for this project is now available from the Authority’s website, specifically at: http://www.thruway.ny.gov/netdata/contractors/documents/d214922_tas24-21b_supplemental-information-12-04-2024.zip

An updated quantity workup for Item 556.03 is now available.

PROPOSAL

1. **CHANGE** the estimated quantity for the following Item:

<u>Contract Proposal Page</u>	<u>Item No.</u>	<u>Description</u>	<u>Unit</u>	<u>Initial Estimated Quantity</u>	<u>Revised Estimated Quantity</u>
193	556.03	Stud Shear Connectors for Bridges	EA.	14,800	16,300

The “paper” Bidder shall **CROSS OUT** the estimated quantity shown for these items in the Contract Proposal, **WRITE IN** the revised estimated quantity, and submit its bid based on the noted changes. If the Bidder fails to make these changes, the Authority will do so and adjust the BID AMOUNT for the items and TOTAL BID, accordingly.

PLANS

2. On Drawing ST-10, Sheet 49 of 235, **ADD** “NOTE 4. THE MOMENT DEMAND FOR THE TEMPORARY SHEET PILING IS 147.8 K-FT. AND THE SECTION MODULUS FOR 50 KSI STEEL IS 59.2 CUBIC INCHES.”

The Bidder **MUST** complete Page **219** of the Proposal acknowledging receipt of this amendment. If the Bidder fails to complete the “Amendment Acknowledgement” sheet, his bid could be declared informal thereby delaying award of the contract.

PLEASE BE GOVERNED ACCORDINGLY WHEN SUBMITTING BIDS.

Brent E. Howard, P.E.
Chief Engineer